

## **ORDER OF AN EXECUTIVE OFFICER Boil Water Order**

**To:** Village of Stirling  
“the Owner”

&

Scott Donselaar  
“the Owner”

**RE:** The Drinking Water Supply located in Stirling, Alberta and municipally described as:  
Village of Stirling

**WHEREAS** I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

**AND WHEREAS** such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. On October 25, 2023, the Village of Stirling experienced a planned depressurization of the potable water distribution system. The Village’s potable water distributions system was depressurized for an extended period of time.

**AND WHEREAS** such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. On October 25, 2023, the Village of Stirling experienced a planned depressurization of the potable water distribution system. The Village’s potable water distributions system was depressurized for an extended period of time. This is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.

**AND WHEREAS** by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

**NOW THEREFORE**, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issues a Boil Water Advisory to all users of the above noted Drinking Water Supply.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:

- a. Complete the necessary repairs of the potable water infrastructure in accordance with Alberta Environment and Protected Areas (AEPA) requirements and direction.
  - b. Complete the required flushing of the potable water distribution system in accordance with AEPA requirements and direction.
  - c. After flushing of the distribution system has been completed, two sets of satisfactory bacteriological water samples taken at least 24 hours are required. Bacteriological water samples must be submitted to the Alberta Provincial Laboratory of Public Health and be representative of the potable water distribution system, in accordance with AEPA requirements and direction.
3. The work referred to in paragraph 2 shall be completed by October 27, 2023.
  4. That, until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Lethbridge, Alberta, October 25, 2023

Confirmation of a verbal order issued to Scott Donselaar on October 25, 2023



Sean Robison CPHI(C)  
Executive Officer  
Alberta Health Services

You have the right to appeal

A person who      a) is directly affected by a decision of a Regional Health Authority, and  
                             b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board  
c/o Central Reception  
Main Floor, ATB Place North Tower  
10025 Jasper Avenue NW  
Edmonton, Alberta, T5J 1S6  
Phone: 780-222-5186  
Fax: 780-422-0914  
Email: [HealthAppealBoard@gov.ab.ca](mailto:HealthAppealBoard@gov.ab.ca)  
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

**Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>**

Template revised September 12, 2022

Copy Alberta Environment and Protected Areas

---

Lethbridge • Lethbridge Community Health • Environmental Public Health

801 1 Avenue S. Lethbridge, Alberta, Canada T1J 4L5

[www.ahs.ca/eph](http://www.ahs.ca/eph)

PSD-0315-202205